



182 GRANITE STREET, SUITE 101, CORONA, CA 92879

PHONE: (951)278-1830 FAX: (951)278-8444 www.canfab.com canfab@canfab.com

TEMPSTAR 6 - 12 1/2 TON


72-120, RAS 90-150, RGH 72-120, RGS 90-150,
RHH 72-102, RHS 90-120

RAH

PART NO: SEE BELOW

ROOF CURB SERVICE PLATE CONNECTIONS

REPLACES CF*****SPC



SELECT PRODUCT



A	B	PART NUMBER
1" FPT	3/4" FPT	1007-SPC

FEATURES

- USED FOR POWER AND CONTROL WIRING TO REDUCE THE NUMBER OF ROOF PENETRATIONS NEAR THE CURB.
- INSTALL BEFORE CURB IS FLASHED. USE SCREWS, FIELD PROVIDED, TO ATTACH TO WOOD NAILER.
- CONNECT CONDUIT TO INSIDE OF CURB BEFORE UNIT IS SET.
- AFTER UNIT IS SET COMPLETE CONDUIT THRU UNIT BASE RAIL TO SERVICE ENTRY KNOCK OUTS. SEE CARRIER UNIT LITERATURE.
- HOLE PROVIDED FOR GAS PIPING. SERVICE PLATE, PIPING AND COUPLINGS FOR GAS PIPING BY OTHERS.

PROJECT:

DATE:

ENGINEER:

DISTRIBUTOR:

DRAWING NUMBER: